



AMARILLO AREA PUBLIC HEALTH DISTRICT

Cities of Amarillo, Canyon, the Villages of Timbercreek Canyon, Lake Tanglewood,
Palisades, the Town of Bishop Hills, and Potter and Randall County
CITY OF AMARILLO, P.O. BOX 1971, AMARILLO, TX, 79105-1971

June 25, 2025
Joseph Harless
100 Cedar Lane

Reference: Existing septic system results for 100 Cedar Ln Amarillo TX 79118-9324, PRAD # 142164 LAKE TANGLEWOOD, BLK 0001, 26A LESS SE 21.44FT TRI ALL OF 27A & NW 33.17FT TRI OF 25A, 2.0000 ACRES.

Dear Mr. Harless

The septic system was originally inspected and approved on April 4, 2002. This septic system was designed to accommodate a 4-bedroom 3680 sq ft home. The original entire file may be located at: <https://www.amarillo.gov/environmental-health/on-site-sewage-facility/> - "Steps for accessing online septic records for Potter & Randall Counties:" – Permit # 2009-099.

The system consists of a 1250-gallon poly tank with an absorption field. The system met minimal state requirements at the time of construction. A site inspection was conducted on June 25, 2025, however, no excavations of this system were undertaken. The surface area of the drain field did not reveal any signs of saturation and the drainfield was probed with no observable percolation. No settlement was observed over the drainfield.

Upon investigation, the tank was accessible and able to be inspected. The clean-out was secure with no visible signs of discharge or saturated soil. During the inspection it was noted that a sprinkler system is located over the system, lids to the tank were not secure and there was no secondary containment. It is recommended to use the sprinkler system sparingly to avoid over saturation of the system, lids to the tank be secured and secondary containment be placed.

The On-Site Sewage Facilities are considered to be in compliance with the requirements of Chapter 285 as inspected and approved on April 22, 2002.

If you have any questions, please contact our office at 806-378-9472 Option 6.

Sincerely,
Carter West
OSSF Program Manager
Designated Representative OS0038976

Potter and Randall County are the Authorized Agents for TCEQ (State of Texas Commission on Environmental Quality.) The City of Amarillo Environmental Health Department is the Designated Representative for Potter and Randall Counties and handles all the permitting, inspection, and regulation of OSSF systems for these Counties.

cc: joesharless@gmail.com
gm@laketanglewood.org